

# PREVENTIVE MAINTENANCE FOR BEAM PUMPING EQUIPMENT

*DENNY B. BULLARD*  
*Continental Oil Company*

## INTRODUCTION

A Preventive Maintenance (PM) Program has been established in the southeastern New Mexico portion of Continental Oil Company's production department operation. The PM system has been in operation for 12 months and covers over 2000 separate pieces of major surface equipment.

The concept of preventive maintenance is not new in production operations; however, most operating organizations incorporate PM and operations in one organization. The primary disadvantage of this type of setup is the secondary priority PM receives. Day-to-day operating problems normally receive first priority and PM work is done after the "emergencies" are handled. For that reason, Conoco's "PM" organization has been separated from the "operations" organization.

Preventive maintenance is the systematic inspection, cleaning, lubrication, and servicing of equipment. The objective of PM is to prevent malfunctions and breakdowns, with the result that all mechanical equipment will work as well and as long as it should with minimum repairs.

Operations include those tasks that have to be done to efficiently produce oil and gas wells, to monitor and control oilfield facilities, to answer alarms, and to assure that environmental and safety standards are maintained. An efficient production operation must give equal priority to operational tasks and PM.

This paper deals only with the PM for beam pumping equipment. However, the procedures followed in establishing the PM for the beam pumping equipment are essentially the same for all pieces of equipment included in this project.

## PM ORGANIZATION

The PM work for all of the equipment covered is under the direction of a PM foreman. Four two-man crews and a test engineer are assigned to the PM production foreman. Two of these crews handle PM on waterflood equipment, one crew is assigned tank battery equipment, and pumping units are serviced by the fourth two-man team. The test engineer uses specialty test equipment such as vibration analyzers on all equipment in the field.

Each PM team also handles "breakdown" repair work on the equipment assigned to them. Fifty percent of their time is allocated to scheduled preventive maintenance with the remainder of their time reserved for emergency work. The 50 percent scheduling factor was based on refinery and plant experience with PM programs. Major repair work, such as pumping unit bearing repair, is handled by

PUMPING UNITS  
PREVENTIVE MAINTENANCE CHECKLIST

Item	Inspection Interval	Routine Servicing or Preventive Maintenance
1. Check oil level in gearbox	Monthly	R
2. Check for oil seal leaks		R
3. Inspect belts for wear		R
4. Look for foundation movement or cracks		R
5. Inspect stuffing box and polished rod		R
6. Clean equipment and location as needed		R
7. Lubricate wire line		R
8. Clean breather cap on gearbox		R
9. Check operation of shutdown switches		R
10. Inspect wellhead ground		R
11. Visual inspection of gearbox oil	Semi-annual	P
12. Lubricate structural bearings		P
13. Check structural and foundation bolts		P
14. Check unit for proper alignment		P
15. Grease brake cable and adjust		P
16. Check counterbalance	Annual	P
17. Check V-belt drive for alignment and wear		P
18. Check ladder bolts and ladder condition		P
19. Check guards on unit		P
20. Change oil in gearbox		P

FIGURE 1

local contractors. The PM team inspects each repair job to maintain quality control on contract services.

## PM PROCEDURES AND EQUIPMENT MANUALS

The inspection procedures to be followed on each pumping unit are included in a PM "Procedures Manual". This manual includes what to check, how often to check it, and who should perform each inspection. In determining what inspections should be made, manufacturers' recommendations were used as a base and were modified by data from

Conoco's maintenance, engineering and marketing departments. Field production foremen then thoroughly reviewed these recommendations and modified them as their experience dictated.

The PM checklist from the "Procedures Manual" for pumping units is shown on Fig. 1. The first ten inspections on this list are denoted "Routine Servicing" (R) and are done by the lease operator. These are the most frequent inspections (monthly), requiring shorter times to complete. These inspections include checking the oil level in the gearbox, looking for obvious oil seal leaks, checking for worn belts, foundations movement, loose

### PUMPING UNITS HOBBS DIVISION - IHM -

### PREVENTIVE MAINTENANCE SCHEDULE LITTLEFIELD 1ST HALF OF FEB. 1976

LEASE	LOCATION	EQUIPMENT DESCR.	TYPE INSP.	DATE MAINT. COMPLETED	COMPLETED BY	FILE NO.
REED B	WELL 3	PUMPING UNIT	1 SA	-----	-----	1675
REED B	WELL 7	PUMPING UNIT	1 SA	-----	-----	1681
REED B	WELL 10	PUMPING UNIT	1 SA	-----	-----	1685
REED B	WELL 11	PUMPING UNIT	1 SA	-----	-----	1687
REED B	WELL 12	PUMPING UNIT	1 A	-----	-----	1690
REED B	WELL 13	PUMPING UNIT	1 SA	-----	-----	1691
REED SANDERSON UNIT	WELL 2	PUMPING UNIT	1 SA	-----	-----	1693
REED SANDERSON UNIT	WELL 4	PUMPING UNIT	1 SA	-----	-----	1695
REED SANDERSON UNIT	WELL 5	PUMPING UNIT	1 SA	-----	-----	1697
REED SANDERSON UNIT	WELL 7	PUMPING UNIT	1 SA	-----	-----	1699
REED SANDERSON UNIT	WELL 9	PUMPING UNIT	1 SA	-----	-----	1701
REED SANDERSON UNIT	WELL 13	PUMPING UNIT	1 SA	-----	-----	1703
REED SANDERSON UNIT	WELL 15	PUMPING UNIT	1 SA	-----	-----	1705
REED SANDERSON UNIT	WELL 17	PUMPING UNIT	1 SA	-----	-----	1707
REED SANDERSON UNIT	WELL 19	PUMPING UNIT	1 SA	-----	-----	1709
SANDERSON A	WELL 1	PUMPING UNIT	1 SA	-----	-----	1711
SANDERSON A	WELL 2	PUMPING UNIT	1 SA	-----	-----	1713
SANDERSON A	WELL 3	PUMPING UNIT	1 SA	-----	-----	1715
SANDERSON A	WELL 4	PUMPING UNIT	1 SA	-----	-----	1717
SANDERSON A	WELL 6	PUMPING UNIT	1 SA	-----	-----	1719
SANDERSON A	WELL 7	PUMPING UNIT	1 SA	-----	-----	1721
SANDERSON A	WELL 8	PUMPING UNIT	1 SA	-----	-----	1723
SANDERSON A	WELL 10	PUMPING UNIT	1 SA	-----	-----	1725
SANDERSON A	WELL 11	PUMPING UNIT	1 SA	-----	-----	1727
SANDERSON A	WELL 13	PUMPING UNIT	1 SA	-----	-----	1729
SANDERSON A	WELL 14	PUMPING UNIT	1 SA	-----	-----	1731

FIGURE 2

The “Preventive Maintenance” (P) procedures in Fig.1 are done by the two-man PM team assigned specifically to pumping units. These inspections are less frequent (semiannual and annual) and require more time to perform. In general, any inspection requiring longer than one man-hour is done by the PM team.

A gearbox oil change is called for on an annual basis. Currently, the oil in the gearboxes is being spot-tested to see if this interval can be lengthened. This testing is done by the marketing department

The “Procedures Manual” also contains details of the procedures to be followed for each itemized inspection. A companion “Equipment Manual” has the manufacturers’ operating manuals for each piece of equipment to supplement the procedures in the Procedures Manual.

Individuals were selected for PM work who demonstrated an aptitude for mechanical work. An inventory of field personnel was made to determine which individuals would be better suited for maintenance work and which would have more of an aptitude for operational work.

Manufacturers' representatives were consulted for training assistance. They provided training sessions demonstrating proper lubrication techniques, details of bearing assembly, and general maintenance techniques.

FIGURE 3

The PM team assigned to pumping units utilizes a three-quarter ton truck equipped with a 1500-lb capacity electric hoist, pneumatic grease gun with air compressor, and hand tools necessary to perform the PM inspections. Tools unique to this vehicle include large hammer wrenches necessary to tighten structural and base bolts. A larger truck with gin poles has been proposed to assist in lifting larger belt guards and to hoist oil drums when changing gearbox oil.

With a system such as this, a workable scheduling and record-keeping system is vital. Two separate in-house computer programs have been developed for this purpose.

In the event that not all of the two weeks' work is completed, the inspections not done will automatically be scheduled as first priority for the next two-week period.

Although the malfunction report is now being used, the entire program to assimilate the malfunction information is not completed. When completed, this program will be used to identify

## RESULTS

First, a number of mechanical problems with the pumping units were corrected on the first inspection. These problems included structural bolts missing or loose, grease seals needing replacement, units misaligned, bearings needing repair, and units with improper or inadequate tie-downs. These were

	EQUIPMENT	CODE		EQUIPMENT	CODE
A	ACTUATOR	0 0 1	P	PACKING	0 6 0
		0 0 2		PIPE	0 6 1
		0 0 3		PLUNGER	0 6 2
		0 0 4		POLISH ROD CLAMP	0 6 3
B	BEARING	0 0 5		PROBE	0 6 4
	CRANKPIN	0 0 6		PULSATION DAMPENER	0 6 5
	EQUALIZER	0 0 7		PUMP	0 6 6
	SADDLE	0 0 8	*	PUMP UNIT TIE DOWN	0 6 7
	OTHER	0 0 9		PONY ROD	0 6 8
	BELTS	0 1 0			0 6 9
	BRAKE	0 1 1	R	RECORDER	0 7 0
	BRIDLE	0 1 2		REGULATOR	0 7 1
	BEARING, ROLLER	0 1 3		RELAY	0 7 2
	BEARING, CONN. ROD	0 1 4			0 7 3
		0 1 5			0 7 4
C	CABLE	0 1 6	S	SAMPLER	0 7 5
	CATHODIC PROTECTION	0 1 7		SCRUBBER	0 7 6
	CHEM PUMP	0 1 8		SHEAVE	0 7 7
	CHOKE	0 1 9		SOLENOID	0 7 8
	COMPRESSOR	0 2 0		STING BOX	0 7 9
	CONTROL PANEL	0 2 1		STRAINER	0 8 0
	CONTROLLER	0 2 2	*	STRUCTURAL DAMAGE	0 8 1
	COUPLING	0 2 3			0 8 2
	CROSS HEAD	0 2 4			0 8 3
	CRANK SHAFT	0 2 5	T	TANK	0 8 4
	CONN. ROD	0 2 6		TIMER	0 8 5
D	DIAPHRAGM	0 2 7		TRANSFORMER	0 8 6
		0 2 8			0 8 7
		0 2 9	V	VALVE	
E	ELECTRIC GRND	0 3 0		BLOCK	0 8 8
	ENGINE	0 3 1		BUTTERFLY	0 8 9
		0 3 2		CHECK	0 9 0
		0 3 3		GATE	0 9 1
F	F/N DEVICE	0 3 4		HYD/PNEU	0 9 2
	FILTER	0 3 5		MOTOR	0 9 3
	FIRE TUBE	0 3 6		PLUG	0 9 4
	FUSE	0 3 7		THROTTLING	0 9 5
	FLUID END	0 3 8		WING	0 9 6
	FLUID END HEADS	0 3 9		SUCTION	1 0 2
		0 4 0		DISCHARGE	1 0 3
G	GASKET	0 4 1		BALL & SEAT	1 0 4
	GAUGE	0 4 2		VALVE VERIF SWITCH	0 9 7
	GEAR BOX	0 4 3		VAPOR RECOVERY UNIT	0 9 8
	GREASE SEAL	0 4 4		VESSEL	
		0 4 5		HEATER TRT	0 9 9
H	HEAD-TUBING	0 4 6		SEPARATOR	1 0 0
	HEAD-CASING	0 4 7		GLYCOLATN	1 0 1
		0 4 8			1 0 5
L	LUBRICATOR	0 4 9	W	WIRING	1 0 6
	LUBE PUMP	0 5 0			1 0 7
		0 5 1			1 0 8
M	METER-ORF	0 5 2			1 0 9
	METER-P.D.	0 5 3			1 1 0
	METER-TURB	0 5 4			1 1 1
	MONITOR BSW	0 5 5			1 1 2
	MOTOR	0 5 6			1 1 3
	MURPHY HI-LO OIL SW	0 5 7			1 1 4
		0 5 8			1 1 5
		0 5 9			1 1 6

236

problems that had accumulated over a period of years. Because of the number of problems to be corrected initially, the first six-month inspections actually required nine months to complete. The average time per unit now being spent on the second six-month inspection is considerably less than the first time since the major repair work has already been done. It now appears that only minor adjustment will have to be made to meet the six-month inspection frequency.

A second readily visible benefit of the program is the experience gained by the PM team working with the pumping units. These men, after one year of working strictly with pumping units, can now do a better, more efficient job of servicing the units and can make much better judgments as to the remaining life of unit bearings thus helping to reduce repair and maintenance costs.

The PM team also is doing work that allows the lease operator to concentrate more on operational work.

It has been obvious to us that PM will not stop all mechanical failures. However, with time, we should see a decrease in total failures and in failure frequency.

## CONCLUSIONS

PM for beam pumping equipment can be useful in

helping to extend the life of the equipment. With the proper field organization, PM work can receive priority as well as day-to-day operational work. The true payout of an effective program will take several years to be realized because of the relatively long (20 years) design life of the equipment.

## BIBLIOGRAPHY

1. API Specification for Oil Field V-Belting. API Standard 1 B, Mar., 1974, API Div. of Prod.
2. API Recommended Practice for Installation and Lubrication of Pumping Units. API RP11G, Second Edition, Feb. 1969, API Div. of Prod.
3. Air Balanced Pumping Unit. General Specifications and Operating Instructions A-66, Lufkin Ind.
4. Conventional Pumping Units. Operating Manual CU73, June 1973, Lufkin Ind.
5. Mark II Unitorque Pumping Unit. Operations Manual M-65, Aug. 1965, Lufkin Ind.
6. Oilwell GR Series Pumping Units. Care and Operating Manual, Booklet M37-962, Oilwell Supply Div. of U.S. Steel.
7. Pumping Unit Preventive Maintenance - Monthly Engineering Letter. D.B. Bullard, Jan. 12, 1973.

